

Approval Number 250655018
Test Report: J-00494741, J-00494743, 25.9809, 25.9810, 25.21501
& 25.21502



Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

25th June 2025

Ashutosh Rubber Pvt. Ltd.
2515 - 2516, Lodhika GIDC Industrial Estate,
Inside First Gate,
H-1 Road,
Metoda,
Kalawad Road,
Rajkot - 360 021,
Gujarat,
India

WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

RUBBERS- ETHYLENE PROPYLENE DIENE MONOMER (EPDM) - MATERIAL ONLY.

5365

'ASHUTOSH EPDM 50' & 'ASHUTOSH EPDM 80'. Black coloured, compression moulded EPDM materials with a shore hardness of 50 & 80. Tested in-radius size 1.2mm. For use with water up to 23°C.

APPROVAL NUMBER: 250655018
APPROVAL HOLDER: ASHUTOSH RUBBER PVT. LTD.

The Scheme reserves the right to review approval.
Approval 250655018 is valid between June 2025 and June 2030

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', with a stylized flourish at the end.

Ian Hughes
WRAS Approvals Manager